

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	14
gravel	14	38
limestone	38	48

Total Depth **48**

Casing: 6" PVC from 0' to 42'

Grout: CEMENT from 0 to 44

Water from limestone at 44' to 48'

Static level 8' below casing top which is 1' above GL

Pumping level 40' when pumping at 12 gpm for 2 hr(s)

Permanent pump installed at 40' on 12/23/2015, with a capacity of 22 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 21908 Helen Plainfield, IL

Address of well: same as above

Add'l loc info: Subdivision: Cristeen

Location source: Aerial Photograph verified

Verified by: VJA on 11/2/2016

Permit Date: December 17, 2015 **Permit #:** 197-131-15

COMPANY Dick's Well & Pump

FARM Pedersen, Mark

DATE DRILLED December 22, 2015 **NO.**

ELEVATION 146' GL **COUNTY NO.** 46032

LOCATION

LATITUDE 41.602459 **LONGITUDE** -88.151199

COUNTY Will **API#** 1219746032 00 **13-36N-9E**