

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay brown	0	12
blue clay & boulders	12	33
limestone	33	590

Total Depth **590**

Casing: 6" STEEL T/C from -1' to 34'
 4.5" PVC S/L from 20' to 280'

Grout: MOUNDED BENTONITE from 4 to 34

Water from limestone at 540' to 590'

Static level 290' below casing top which is 1' above GL

Pumping level 340' when pumping at 11 gpm for 8 hr(s)

Permanent pump installed at 385' on 4/7/2014, with a capacity of 12 gpm

Remarks: Driller's Estimated Well Yield 16 gpm

Owner Address: 8000 SE PP Hwy Lawson, IL

Address of well: 35249 Hillview Dr. Wilmington, IL 60481 Wilmington IL

Location source: Global Positioning System verified

Verified by: VJA on 5/18/2017

Permit Date: February 4, 2014

Permit #: 197-004-14

COMPANY Doyle, Gerald

FARM Spangler, John

DATE DRILLED April 7, 2014

NO. 1

ELEVATION '

COUNTY NO. 46043

LOCATION

LATITUDE 41.245273

LONGITUDE -88.082883

COUNTY Will

API# 1219746043 00

21-32N-10E