

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay over border	0	42
broken liner	42	44
lime	44	300

Total Depth 300

Casing: 8" STEEL from -2' to 46'

Grout: NEAT CEMENT from 0 to 46

Water from limestone at 80' to 300'

Static level 10' below casing top which is 2' above GL

Pumping level 36' when pumping at 55 gpm for 4 hr(s)

Permanent pump installed at ' on , with a capacity of gpm

Remarks: Driller's Estimated Well Yield 100 gpm

Owner Address: 302 N. Chicago St. Joliet, IL

Address of well: 29919 Prairieview Dr. Wilmington, IL 60481
Wilmington IL

Location source: Global Positioning System verified

Verified by: VJA on 4/10/2018

Permit Date: August 18, 2017

Permit #: 197-087-17

COMPANY Wehling, Richard W.

FARM Will County Executive

DATE DRILLED September 1, 2017

NO. 1

ELEVATION '

COUNTY NO. 46594

LOCATION

LATITUDE 41.345213

LONGITUDE -88.116763

COUNTY Will

API# 1219746594 00

18-33N-10E