

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay fill	0	5
clay	5	25
sand	25	35
clay	35	60
sand & gravel	60	72
limestone	72	180

Total Depth **180**

Casing: 5" PVC SDR 21 from -1' to 75'

Grout: ENVIROGROUT from 0 to 75

Water from limestone at 75' to 180'

Static level 20' below casing top which is 1' above GL

Pumping level 20' when pumping at 22 gpm for 2 hr(s)

Permanent pump installed at 60' on 2/11/2019, with a capacity of 22 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 6458 North Peotone Rd. Peotone, IL

Address of well: same as above

Location source: Global Positioning System verified

Verified by: VJA on 9/5/2019

Permit Date: January 3, 2019

Permit #: 197-002-19

COMPANY Sharpe, Franklin N.

FARM Zigtema, Greg

DATE DRILLED January 17, 2019

NO.

ELEVATION '

COUNTY NO. 46903

LOCATION

LATITUDE 41.355525

LONGITUDE -87.768769

COUNTY Will

API# 1219746903 00

7-33N-13E