

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	18
gray clay	18	60
gravel	60	72
limestone	72	140

Total Depth **140**

Casing: 6" PVC GLUE from 0' to 76'

Grout: BENTONITE from 0 to 73

Water from limestone at 140' to 0'

Static level 40' below casing top which is ' above GL

Pumping level 90' when pumping at 20 gpm for 1 hr(s)

Permanent pump installed at 80' on 11/7/2020, with a capacity of 20 gpm

Remarks: Driller's Estimated Well Yield 30 gpm

Owner Address: 16447 New Castle Way Lockport, IL

Address of well: 17437 S McCarron Rd Homer Glen, IL 60491 Homer Glen IL

Location source: Global Positioning System verified

Verified by: VJA on 9/1/2022

Permit Date: May 11, 2020

Permit #: 197-0028-20

COMPANY Senffner, Alan James

FARM Lamb, Derek & Alissa

DATE DRILLED November 5, 2020

NO.

ELEVATION 712' GL

COUNTY NO. 47217

LOCATION

LATITUDE 41.570483

LONGITUDE -87.985795

COUNTY Will

API# 1219747217 00

28-36N-11E