

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	50
sandstone	50	160

Total Depth **160**

Casing: 6" PLASTIC SDR 21 from 0' to 65'

5" PLASTIC SDR 21 from 65' to 160'

Grout: NEAT from 0 to 65

Size hole below casing: 6"

Water from sandstone at 140' to 150'

Static level 10' below casing top which is 2' above GL

Pumping level 100' when pumping at 40 gpm for 4 hr(s)

Permanent pump installed at 146' on 9/30/1992, with a capacity of 40 gpm

Owner Address: P.O. Box #206 Johnson City, IL

Location source: Location from permit

Permit Date: June 5, 1992

Permit #: 021990

COMPANY Geer, James A.

FARM Imhoff, John

DATE DRILLED September 30, 1992

NO.

ELEVATION 0'

COUNTY NO. 23504

LOCATION

LATITUDE 37.829600

LONGITUDE -88.952467

COUNTY Williamson

API# 1219923504 00

14-8S-2E