

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
loam	0	3
gray clay	3	60
limestone	60	180

Total Depth **180**

Casing: 5" ASTM 53 from 0' to 60'

Size hole below casing: 5"

Water from limestone at 60' to 180'

Static level 35' below casing top which is 2' above GL

Pumping level 40' when pumping at 10 gpm for 0 hr(s)

Permanent pump installed at 60' on 10/12/1994, with a capacity of 10 gpm

Owner Address: 554 Homestead Rockford, IL

Address of well: same as above

Location source: Location from permit

Permit Date: October 6, 1994

Permit #: 1376

COMPANY Smeja, Robert B.

FARM Kegal, Mark

DATE DRILLED October 10, 1994

NO.

ELEVATION 0'

COUNTY NO. 31373

LOCATION

LATITUDE 42.181833

LONGITUDE -89.171761

COUNTY Winnebago

API# 1220131373 00

19-43N-1E