

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	5
clay loam	5	60
lime rock	60	125

Total Depth **125**

Casing: 5" STEEL A53B from 0' to 63'

Grout: BENSEAL from 0 to 50

Water from rock at 63' to 125'

Static level 10' below casing top which is 1' above GL

Pumping level 20' when pumping at 10 gpm for 4 hr(s)

Permanent pump installed at 0' on 7/20/1998, with a capacity of 0 gpm

Owner Address: 6705 W. State St. Rockford, IL

Address of well: same as above

Location source: Location from permit

Permit Date: July 16, 1998

Permit #: 2294

COMPANY Hinkle, James A.

FARM Johnson, George

DATE DRILLED July 15, 1998

NO. 1

ELEVATION 0'

COUNTY NO. 31447

LOCATION

LATITUDE 42.279964

LONGITUDE -89.172087

COUNTY Winnebago

API# 1220131447 00

19-44N-1E