

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
sand	2	40
gravel	40	75

Total Depth

75

Casing: 5" ASTM A53B from -1' to 70'

Screen: 5' of 5" diameter 15 slot

Grout: NONE NEEDED from 0 to 75

Water from gravel at 70' to 75'

Static level 22' below casing top which is 1' above GL

Pumping level 25' when pumping at 14 gpm for 3 hr(s)

Permanent pump installed at 0' on 5/1/1999, with a capacity of 0 gpm

Owner Address: 213 Seneca Rockford, IL

Address of well: same as above

Location source: Location from permit

Permit Date: April 27, 1999

Permit #: 2459

COMPANY Martin, Charles Leroy

FARM Sholes, LaVerne

DATE DRILLED April 29, 1999

NO.

ELEVATION 0'

COUNTY NO. 31557

LOCATION

LATITUDE 42.227713

LONGITUDE -89.112235

COUNTY Winnebago

API# 1220131557 00

3-43N-1E