

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
sand & gravel	2	85

Total Depth **85**

Casing: 5" ASTM A53B from -1' to 85'

Screen: 4' of 5" diameter 15 slot

Water from sand & gravel at 80' to 85'

Static level 30' below casing top which is 1' above GL

Pumping level 40' when pumping at 12 gpm for 3 hr(s)

Permanent pump installed at 0' on 5/15/1999, with a capacity of 0 gpm

Owner Address: 1150 Dearborn Ave. So. Beloit, IL

Address of well: same as above

Location source: Location from permit

Permit Date: May 10, 1999

Permit #: 2471

COMPANY Martin, Charles Leroy

FARM Cliffe, Terry

DATE DRILLED May 15, 1999

NO.

ELEVATION 0'

COUNTY NO. 31579

LOCATION

LATITUDE 42.483051

LONGITUDE -89.020297

COUNTY Winnebago

API# 1220131579 00

8-46N-2E