

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	7
soft yellow lime	7	46
yellow & gray lime	46	107
gray	107	243
Glenwood	243	260
sandstone	260	270

Total Depth **270**

Casing: 6" CERTALOK from 0' to 80'

Grout: CLAY from 0 to 80

Water from sandstone at 260' to 270'

Static level 60' below casing top which is 1' above GL

Pumping level 110' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 180' on 9/28/2001, with a capacity of 20 gpm

Remarks: driller's est well yield 100 gpm

Owner Address: 2285 W. State Street Seward, IL

Address of well: same as above

Location source: Location from permit

Permit Date: June 21, 2001

Permit #: 2854

COMPANY Allabaugh, John H.

FARM New Life Bible Church

DATE DRILLED October 1, 2001

NO.

ELEVATION 0'

COUNTY NO. 32113

LOCATION

LATITUDE 42.283386

LONGITUDE -89.301624

COUNTY Winnebago

API# 1220132113 00

2-26N-10E