

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
sandy clay	2	10
sand & gravel	10	60

Total Depth **60**

Casing: 5" STEEL from -1' to 57'

5" STAINLESS STL SCREEN from 57' to 60'

Screen: 3' of 5" diameter 15 slot

Water from sand & gravel at 57' to 60'

Static level 25' below casing top which is 1' above GL

Pumping level 40' when pumping at 18 gpm for 48 hr(s)

Permanent pump installed at 40' on 2/6/2006, with a capacity of 12 gpm

Remarks: driller's est. well yield 25 gpm

Owner Address: 6903 Will James Rd. Rockford, IL

Address of well: same as above

Add'l loc info: Lot: 1 Subdivision: James Country Homes

Location source: Location from permit

Permit Date: January 30, 2006

Permit #:

COMPANY C. Martin & Sons Well Co.

FARM Burkell, Carl F.

DATE DRILLED February 3, 2006

NO.

ELEVATION 0'

COUNTY NO. 32695

LOCATION

LATITUDE 42.180721

LONGITUDE -89.085356

COUNTY Winnebago

API# 1220132695 00

23-43N-1E