

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown clay	0	40
broken limestone	40	80
rotten red sandstone	80	120
brown sandstone	120	150
white sandstone	150	200
pink sandstone	200	225
white sandstone	225	275

Total Depth **275**

Casing: 6" STEEL from 0' to 120'

Grout: VOLCLAY from 0 to 0

Static level 55' below casing top which is 2' above GL

Pumping level 80' when pumping at 35 gpm for 24 hr(s)

Permanent pump installed at 110' on 2/15/2004, with a capacity of 22 gpm

Remarks: driller's est well yield 200 gpm

Owner Address: 13169 Trask Bridge Rd. Durand, IL

Address of well: same as above

Location source: Location from permit

Permit Date: September 26, 2003 **Permit #:**

COMPANY Allabaugh, Neil M.

FARM Bridges, Tim

DATE DRILLED February 25, 2004 **NO.**

ELEVATION 0' **COUNTY NO.** 32761

LOCATION

LATITUDE 42.376613 **LONGITUDE** -89.299980

COUNTY Winnebago **API#** 1220132761 00 **36-28N-10E**