

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
clay & sand gravel	2	51
limestone	51	138
gray dolomite	138	240

Total Depth **240**

Casing: 6" PLASTIC from 0' to 72'

Grout: BENTONITE from 0 to 70

Water from limestone at 138' to 240'

Static level 30' below casing top which is 1' above GL

Pumping level 60' when pumping at 25 gpm for 3 hr(s)

Permanent pump installed at 190' on 9/7/2014, with a capacity of 40 gpm

Remarks: Driller's Estimated Well Yield 100 gpm

Owner Address: 8961 Springcreek Rd. Rockford, IL

Address of well: same as above

Location source: Aerial Photograph verified

Verified by: VJA on 8/6/2021

Permit Date: August 25, 2014

Permit #: 30834

COMPANY Bloyer Well Co.

FARM Nelson, Karen

DATE DRILLED September 15, 2014

NO.

ELEVATION '

COUNTY NO. 32962

LOCATION

LATITUDE 42.304529

LONGITUDE -88.941286

COUNTY Winnebago

API# 1220132962 00

12-44N-2E