

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clay	0	25
sand & gravel	25	30
gray clay	30	80
limestone & gray rock	80	147
clay seam lots of sand & water	147	150
streaks of limestone & dolomite	150	195

Total Depth **195**

Casing: 5" STEEL ASTM A53B from -1' to 99'
 4" SCH 40 PVC from 135' to 157'

Grout: QUICK GROUT from 0 to 98

Water from limestone at 157' to 195'

Static level 40' below casing top which is 1' above GL

Pumping level 60' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 80' on 11/11/2017, with a capacity of 22 gpm

Remarks: Driller's Estimated Well Yield 25 gpm

Owner Address: 12445 Bellingham Rd. Caledonia, IL

Address of well: 7573 Deer Crossing Roscoe, IL Roscoe IL

Add'l loc info: Lot: 39 Subdivision: Hidden Creek

Location source: Aerial Photograph verified

Verified by: VJA on 10/15/2021

Permit Date: September 27, 2017 **Permit #:** 39289

COMPANY Beaman, Jessie J.

FARM Youssi Construction

DATE DRILLED October 15, 2017 **NO.**

ELEVATION ' **COUNTY NO.** 33139

LOCATION

LATITUDE 42.450557 **LONGITUDE** -88.968912

COUNTY Winnebago **API#** 1220133139 00 **23-46N-2E**