

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	2
yellow clay	2	19
gray clay	19	63
dirty sand & gravel	63	87
gray clay w/ streaks of sand	87	165
sand	165	175
sand & gravel water	175	180

Total Depth **180**

Casing: 5" BLACK 15# from 0' to 176'

Screen: 4' of 5" diameter 20 slot

Water from sand & gravel at 175' to 180'

Static level 46' below casing top which is 1' above GL

Pumping level 46' when pumping at 15 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Driller's Log filed.

Owner Address: 444 W. Fourth St. El Paso, IL

Location source: Location from permit

Permit Date: May 25, 1978

Permit #: 74746

COMPANY Stoneberger, Donald

FARM Dixon, Bob

DATE DRILLED June 12, 1978

NO.

ELEVATION 0'

COUNTY NO. 20754

LOCATION

LATITUDE 40.669186

LONGITUDE -89.002650

COUNTY Woodford

API# 1220320754 00

33-26N-2E