

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
SS #67085 (20'-121')	0	0
fill	0	9
gravel #30 - 1/2"	0	121
gray clay	9	17
coarse yellow sand	17	20
gray gravel	20	53
gray clay	53	99
sandy gray clay	99	102

Total Depth **121**

Casing: 12" STEEL from 0' to 106'

Screen: 15' of 12" diameter 100 slot

Grout: PUDDLED CLAY from 0 to 106

Size hole below casing: 12"

Water from sand at 99' to 121'

Static level 4' below casing top which is 0' above GL

Pumping level 30' when pumping at 380 gpm for 3 hr(s)

Permanent pump installed at 84' on , with a capacity of 380 gpm

Remarks: Springfield permit #0546-FY1989

Sample set # 67085	20' - 53'	Received: 7/9/1990
	102' - 121'	Received: 7/9/1990

Address of well:

Location source: Location from the driller

Permit Date: October 13, 1988 **Permit #:**

COMPANY Albrecht, S. D.

FARM Roanoke, Village of

DATE DRILLED February 19, 1989 **NO.** 6

ELEVATION 0' **COUNTY NO.** 21663

LOCATION 510'N line, 137'W line of SE SE

LATITUDE 40.795055 **LONGITUDE** -89.197634

COUNTY Woodford **API#** 1220321663 00 **15-27N-1W**