

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
topsoil	0	1
yellow clay	1	19
blue clay	19	55
sand	55	69

Total Depth

69

Casing: 4" SCH 40 PVC from 4' to 65'

Screen: 4' of 4" diameter 20 slot

Grout: BENT. BENSEAL from 4 to 64

Water from sand at 55' to 69'

Static level 36' below casing top which is 1' above GL

Pumping level 35' when pumping at 10 gpm for 2 hr(s)

Permanent pump installed at 0' on 4/1/2000, with a capacity of 0 gpm

Owner Address: R.R. 2 Box 20 El Paso, IL

Address of well: same as above

Location source: Location from permit

Permit Date: March 24, 2000

Permit #:

COMPANY Meyer, George J.

FARM Partner, Norma

DATE DRILLED April 1, 2000

NO. 1

ELEVATION 0'

COUNTY NO. 22171

LOCATION

LATITUDE 40.760044

LONGITUDE -89.005536

COUNTY Woodford

API# 1220322171 00

33-27N-2E