

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
black top soil	0	3
yellow clay	3	18
gray clay	18	50
gray sand & gravel	50	60
gray clay	60	121
gray sand & gravel	121	144

Total Depth **144**

Casing: 4" SCH40 GLUED from 1' to 139'

4" SCREEN from 139' to 144'

Screen: 5' of 4" diameter 20 slot

Grout: EASY SEAL from 0 to 130

Water from sand & gravel at 121' to 144'

Static level 111' below casing top which is 2' above GL

Pumping level 112' when pumping at 25 gpm for 3 hr(s)

Permanent pump installed at ' on 7/21/2021, with a capacity of 10 gpm

Owner Address: 5608 Southwest 12th Pl Cape Coral, FL

Address of well: County Rd 275 N Congreville, IL Congreville IL

Location source: Location from the driller

Permit Date: May 21, 2021

Permit #: 203-1957-21

COMPANY Smith, David M.

FARM Nussbaum, Jan

DATE DRILLED July 13, 2021

NO.

ELEVATION '

COUNTY NO. 23531

LOCATION

LATITUDE 40.626920

LONGITUDE -89.223655

COUNTY Woodford

API# 1220323531 00

16-25N-1W