

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
brown loam	0	1
brown sand fine	1	4
brown gravel, coarse to v coarse	4	70
brown sand fine	70	94
brown sand & gravel coarse	94	104

Total Depth **104**

Casing: 5" sr 21 pvc from -2' to 95'

4" screen/ss from 95' to 99'

Screen: 4' of 4" diameter 30 slot

Grout: BENSEAL from 0 to 85

Water from sand/gravel at 39' to 99'

Static level 390' below casing top which is 1' above GL

Pumping level 440' when pumping at 14 gpm for 2 hr(s)

Permanent pump installed at 87' on 5/9/2024, with a capacity of 10 gpm

Remarks:

Owner Address: 1634 CR 800 N Lacon, IL

Address of well: 710 N Chicago St Spring Bay IL

Add'l loc info: Lot: 141 Subdivision:

Location source: Global Positioning System verified

Permit Date: April 22, 2024

Permit #: 203-2076-24

COMPANY Tyler J. Gee

FARM Janssen, Stacy

DATE DRILLED April 30, 2024

NO.

ELEVATION 490'

COUNTY NO. 23673

LOCATION

LATITUDE 40.821167

LONGITUDE -88.481167

COUNTY Woodford

API# 1220323673 00

1-27N-4W