

ILLINOIS STATE GEOLOGICAL SURVEY

Page 1

Water Well	Top	Bottom
clean sand & fine gravel	5	176
sand silt & gravel	6	171
yellow clay	18	18
sandy blue clay, soft	35	120
red clay, firm	45	165
stoney blue clay	67	85

Total Depth **176**

Casing: 4" GALV 11#/' ASTM A53B from 0' to 173'
 3.8" STAINLESS STL SCREEN from 173' to 176'

Screen: 3' of 3.8" diameter 15 slot

Grout: BENTONITE from 0 to 64

Static level 98' below casing top which is 0' above GL

Pumping level 98' when pumping at 20 gpm for 2 hr(s)

Permanent pump installed at 0' on , with a capacity of 0 gpm

Owner Address: 23716 127th St. Salem, WI

Address of well: same as above

gamma file: 127st

Location source: Global Positioning System verified

Verified by: ADW on 8/8/2000

Permit Date:

Permit #:

COMPANY Gross, Michael

FARM Lamb, Noah

DATE DRILLED July 27, 2000

NO.

ELEVATION 825'

COUNTY NO. 00430

LOCATION

LATITUDE 42.496858

LONGITUDE -88.095136

COUNTY Gallatin

API# 4805900430 00

35-1N-20E